



### 1 TYPE EXAMINATION CERTIFICATE

2 Equipment intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Certificate Number: Sira 02ATEX3079 Issue: 4

4 Equipment: Powerheat AHT Constant Power Heating Cable

5 Applicant: Heat Trace Limited

6 Address: Meres Edge

Chester Road Helsby

Frodsham WA6 0DJ

UK

- 7 This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- Sira Certification Service certifies that this equipment has been found to comply with the Essential Health and Safety Requirements that relate to the design of Category 2 equipment, which is intended for use in potentially explosive atmospheres. These Essential Health and Safety Requirements are given in Annex II to European Union Directive 94/9/EC of 23 March 1994.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule of this certificate, has been assessed by reference to:

EN 60079-0:2012 IEC 60079-31:2008 EN 60079-30-1:2007

The above list of documents may detail standards that do not appear on the UKAS Scope of Accreditation, but have been added through Sira's flexible scope of accreditation, which is available on request.

- If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- This TYPE EXAMINATION CERTIFICATE relates only to the design of the specified equipment, and not to specific items of equipment subsequently manufactured.
- 12 The marking of the equipment shall include the following:



II 2 GD Ex e IIC T\* Gb Ex tb IIIC T#°C Db T\* and T#°C (see schedule)

Project Number 25433

This certificate and its schedules may only be reproduced in its entirety and without change.

C. E

C Ellaby Deputy Certification Manager

**Sira Certification Service** 

Rake Lane, Eccleston, Chester, CH4 9JN, England





### **SCHEDULE**

#### TYPE EXAMINATION CERTIFICATE

Sira 02ATEX3079 Issue4

### 13 DESCRIPTION OF EQUIPMENT

#### **AHT Range Heating Cables**

The Powerheat AHT Heating Cables are constant power trace heating cables that are used to protect against freezing or maintain temperatures. The cables are rated at up to 200 W/m on a supply voltage up to 277 V. They comprise two insulated parallel bus wires, around which is wrapped a layer of mica and then glass insulation tape. A resistance wire is spiralled over the core, which is notched at intervals so that the resistance wire connects to the bus wires underneath. A further layer of mica and glass tape insulation is extruded over the top of the resistance wire. The insulation is covered with an aluminium outer jacket, and can have a further, optional, chemical resistant outer jacket.

The heating cables are cut to length to form a unit that is terminated at each end with a seal kit. The equipment is designed to be connected to a supply by means of suitable certified cable entries and junction boxes in accordance with the manufacturer's installation instructions. Additional earthing of the outer jacket may also be achieved by the use of a P clip arrangement. The minimum installation temperature of the heating cables is -40°C. The maximum surface temperature is dependent on the maximum permissible workpiece temperature as shown in the following tables:

Table A (*)		Maximum permissible workpiece temperature						
Maximum surfa	T6	T5	T4	T3	T2	T1		
Product type	Nominal output (W/m)	T85°C	T100°C	T135°C	T200°C	T300°C	T450°C	
AHT	10	34	50	100	188	290	340	
	15	-	36	71	160	289	350	
	30	-	11	28	100	246	323	
	50	-	-	-	39	178	276	
	100	-	-	-	-	48	140	
	150	-	-	-	-	-	36	
	200	-	-	-	-	-	7	

Table B (#)	Maximum Permissible Workpiece Temperature						
Maximum surfa	T6	T5	T4	T3	T2	T1	
Product type	Nominal output (W/m)	T85°C	T100°C	T135°C	T200°C	T300°C	T450°C
AHT	10	40	60	110	190	290	340
	50	-	-	-	-	206	295
	100	-	-	-	-	82	176
	150	_	_	_	_	-	38

Table A: Stabilised design system or Protective System

Table B: Protective system with Heat Trace 'Powermatch' power controller (Where a temperature controller is used to limit the maximum surface temperature, it shall comply with IEC 60079-30:2007 clause 4.4.3.)

The heating cables meet the requirements for degree of protection IP 67.

This certificate and its schedules may only be reproduced in its entirety and without change.

**Sira Certification Service** 

Rake Lane, Eccleston, Chester, CH4 9JN, England





### **SCHEDULE**

## TYPE EXAMINATION CERTIFICATE

Sira 02ATEX3079 Issue4

### Variation 1 - This variation introduced the following changes:

i. The manufacturer's address was changed

From: Heat Trace Limited To: Heat Trace Limited

Tracer House Meres Edge
Cromwell Road Chester Road
Bredbury Helsby

Stockport SK6 2RF Frodsham WA6 0DT

The braid diameter on the cables was altered.

### Variation 2 - This variation introduced the following changes:

i. Following appropriate re-assessment to demonstrate compliance with the requirements of the EN 60079 series of standards, the documents originally listed in section 9, IEC 62086-1:2001, EN 50014:1997 (amendments 1 and 2), EN 50019:2000 and EN 50281-1-1:1998, were replaced by those currently listed, the markings in section 12 were updated accordingly and the conditions were modified to recognise the requirements of the latest standards.

# Variation 3 - This variation introduced the following changes:

- i. Following appropriate re-assessment to demonstrate compliance with the requirements of the latest general requirements standard, EN 60079-0:2009 was replaced by EN 60079-0:2012.
- ii. The use of an optional, chemical resistant outer jacket was endorsed.
- iii. The maximum value of the nominal output (W/m) in 'Table A: Stabilised design system or Protective System' was increased from 150 W/m to 200 W/m, in addition, two new intermediary values, 15 W/m and 30 W/m, were recognised, the Description of Equipment was amended accordingly.
- iv. The addition of Figure 3 in drawing number HC2901/0 to clarify temperature markings of the heating cable.

## 14 DESCRIPTIVE DOCUMENTS

### 14.1 Drawings

Refer to Certificate Annexe.

### 14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	07 March 2003	53A8908	The release of prime certificate.
1	25 April 2006	51A14380	The introduction of Variation 1.
2	01 June 2010	R21959A/00	This Issue covers the following changes:
			<ul> <li>All previously issued certification was rationalised</li> </ul>
			into a single certificate, Issue 2, Issues 0 to 1
			referenced above are only intended to reflect the
			history of the previous certification and have not
			been issued as documents in this format.
			<ul> <li>he introduction of Variation 2.</li> </ul>
3	05 May 2011	N/A	Issued to correct the title of the Annexe
4	13 December 2012	R25433F/00	The introduction of Variation 2

This certificate and its schedules may only be reproduced in its entirety and without change.

**Sira Certification Service** 

Rake Lane, Eccleston, Chester, CH4 9JN, England





### **SCHEDULE**

### TYPE EXAMINATION CERTIFICATE

Sira 02ATEX3079 Issue4

15 SPECIAL CONDITIONS FOR SAFE USE

None

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed reports listed in Section 14.2.

- 17 CONDITIONS OF CERTIFICATION
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of Sira Certificates.
- 17.2 Holders of Type Examination Certificates are required to comply with the production control requirements defined in Article 8 of directive 94/9/EC.
- 17.3 An electric strength test of  $\sqrt{2}$  U +1000 V rms shall be applied between the conductors and the outer, metallic braid/jacket as appropriate for 60 seconds as required by clause 5.1.2 of EN 60079-30-1.
- 17.4 An electric strength test of the polymeric sheath (overjacket) used for corrosion resistance shall be carried out in accordance with the requirements of EN 60079-30-1 clause 5.2.1.
- 17.4 The manufacturer shall verify the output rating for each cable manufactured in accordance with EN 60079-30-1 clause 5.2.2.
- 17.5 The manufacturer shall demonstrate, through their quality program, the thermal safety of the trace heating cable with respect to time as per EN 60079-30-1 clause 5.1.12.

This certificate and its schedules may only be reproduced in its entirety and without change.

**Sira Certification Service**Rake Lane, Eccleston, Chester, CH4 9JN, England

# **Certificate Annexe**

Certificate Number: Sira 02ATEX3079

**Equipment**: Powerheat AHT Constant Power Heating Cable

Applicant: Heat Trace Limited



### Issue 0

Number	Sheet	Rev.	Date	Description
HC2901/s	1 of 1	0	14 Oct 02	AHT specification
BES2-PL	1 of 1	Α	06 Mar 00	BES1 – End seal reference list
BPS3-PL	1 of 1	В	06 Feb 01	BPS3 – Silicone boot power seal reference list
HES2-PL	1 of 1	Α	06 Mar 00	HES2 – Shrink sleeve end seal reference list
HPS2-PL	1 of 1	Α	06 Mar 00	HPS2 – Shrink sleeve power seal reference list

### Issue 1

Number	Sheet	Rev	Date (Sira stamp)	Description
HC2901/S*	1 of 1	1	25 April 06	Powerheat AHT

<sup>\*</sup> This drawing was modified by Sira on 25 April 2006.

### Issue 2

Number	Sheet	Rev	Date (Sira stamp)	Description
HC2901/S	1 of 1	2	25 May 10	Powerheat AHT

Issue 3 No new drawings were introduced.

### Issue 4

Number	Sheets	Rev.	Date (Sira stamp)	Title
HC2901/0	1 of 1	5	12 Dec 12	Sira Certification Drawing For Power Heat AHT

This certificate and its schedules may only be reproduced in its entirety and without change.

**Sira Certification Service**Rake Lane, Eccleston, Chester, CH4 9JN, England