



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx SIR 11.0120 issue No.:1

Certificate history:
Issue No. 1 (2012-3-26)
Issue No. 0 (2012-2-28)

Status: **Current**

Date of Issue: **2012-03-26** Page 1 of 5

Applicant: **Heat Trace Limited**
Meres Edge
Chester Road
Helsby
Frodsham WA6 0DT
United Kingdom

Electrical Apparatus: **Freezstop Super/Failsafe Super (FSS) Self-Regulating Heating Cable**
Optional accessory:

Type of Protection: **Trace Heating, Increased Safety and Dust**

Marking: Applicable for products rated up to 75 W/m and 277 Vmax
Ex e IIC T3 Gb
Ex tb IIIC T200°C Db IP67


Applicable for products rated above 75 W/m and for nominally rated 230 V products powered up to a maximum 277 V
Ex e IIC T2 Gb
Ex tb IIIC T300°C Db IP67

Approved for issue on behalf of the IECEx Certification Body: C Ellaby

Position: Deputy Certification Manager

Signature:
(for printed version)

Date:


2012-03-26

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

SIRA Certification Service
Rake Lane
Eccleston
Chester
CH4 9JN
United Kingdom

sira
CERTIFICATION



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 11.0120

Date of Issue: 2012-03-26

Issue No.: 1

Page 2 of 5

Manufacturer: **Heat Trace Limited**
Meres Edge
Chester Road
Helsby
Frodsham WA6 0DT
United Kingdom

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements
Edition: 6.0

IEC 60079-30-1 : 2007-01 Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
Edition: 1

IEC 60079-31 : 2008 Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'
Edition: 1

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/SIR/ExTR11.0301/00](#)

[GB/SIR/ExTR12.0062/00](#)

Quality Assessment Report:

[GB/SIR/QAR11.0008/00](#)



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 11.0120

Date of Issue: 2012-03-26

Issue No.: 1

Page 3 of 5

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The Freezstop Super/Failsafe Super (FSS) Self-Regulating Heating Cable comprises two parallel buswires housed within a semi-conductive self-limiting matrix. The semi conductive self-limiting matrix is covered with a fluoropolymer jacket which is then protected by an aluminium sheath or a metallic braid of either tinned copper or nickel plated copper. An optional outer jacket of MFA, PFA or Silicone can be specified. The cables are rated at up to 100 W/m and 277 V.

The equipment is designed to be connected to a supply by means of suitable certified cable entries and junction boxes (i.e. Ex e or Ex d) in accordance with the manufacturer's installation instructions. Termination can be made using any suitably certified type termination kit, which fully isolate, insulate and seal the conductive cores.

The heat trace cable is allowed to be used with the termination kits (IECEx SIR 11.0135X, IECEx SIR 11.0136U and IECEx SIR 11.0137X).

See EQUIPMENT (continued) for additional information and Conditions of Manufacture

CONDITIONS OF CERTIFICATION: NO



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 11.0120

Date of Issue: 2012-03-26

Issue No.: 1

Page 4 of 5

EQUIPMENT(continued):

Additional information

Description	Temperature
Max. continuous exposure temperature (Power ON)	225°C
Max. permissible exposure temperature (Power OFF)	225°C
Minimum installation temperature	-40°C

Conditions of manufacture

The Manufacturer shall comply with the following:

1. An electric strength test of $\sqrt{2} U + 1000$ V rms shall be applied between the conductors and the outer braid or jacket as appropriate for 60 seconds as required by clause 5.1.2 of IEC 60079-30-1:2007.
2. An electric strength test of the polymeric sheath (overjacket) used for corrosion resistance shall be carried out in accordance with the requirements of IEC 60079-30-1:2007 clause 5.2.1.
3. The manufacturer shall verify the output rating for each cable manufactured in accordance with IEC 60079-30-1:2007 clause 5.2.2.
4. The manufacturer shall demonstrate, through their quality program, the thermal safety of the trace heating cable with respect to time as per IEC 60079-30-1:2007 clause 5.1.12.



IECEX Certificate of Conformity

Certificate No.: IECEx SIR 11.0120

Date of Issue: 2012-03-26

Issue No.: 1

Page 5 of 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Issue 1 – this Issue introduced the following changes:

1	The product name was changed from Freezestop Super to Freezestop Super/Failsafe Super.
---	--