



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC Certification Scheme for Explosive Atmospheres
for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: issue No.:

Status:

Date of Issue: Page 1 of 4

Applicant: **Heat Trace Limited**
Meres Edge,
Chester Road,
Helsby,
Frodsham
WA6 0DT
United Kingdom

Electrical Apparatus: **Freezstop Extra (FSE) Self Regulating Heating Cables**
Optional accessory:


Type of Protection: **Trace Heating, Increased Safety and Dust**

Marking: **Ex e IIC T4 Gb**
Ex tb IIIC T135°C Db IP67

Approved for issue on behalf of the IECEx Certification Body: **C Ellaby**

Position: **Deputy Certification Manager**

Signature:
(for printed version)



Date:

2012-02-28

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:
SIRA Certification Service
Rake Lane
Eccleston
Chester
CH4 9JN
United Kingdom





IECEX Certificate of Conformity

Certificate No.: IECEx SIR 11.0126

Date of Issue: 2012-02-28

Issue No.: 0

Page 2 of 4

Manufacturer: **Heat Trace Limited**
Meres Edge,
Chester Road,
Helsby,
Frodsham
WA6 0DT
United Kingdom

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-30-1 : 2007-01 Edition: 1	Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
IEC 60079-31 : 2008 Edition: 1	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:
[GB/SIR/ExTR11.0301/00](#)

Quality Assessment Report:

[GB/SIR/QAR11.0008/00](#)



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 11.0126

Date of Issue: 2012-02-28

Issue No.: 0

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The Freezstop Extra (FSE) Self Regulating Heating Cables utilise two parallel buswires within a semi-conductive self-limiting matrix. The semi conductive self-limiting matrix is covered with an insulation jacket which is then protected by an aluminium sheath or a metallic braid of either tinned copper or nickel plated copper. An optional outer jacket of TPE, PE, PVDF, MFA or PFA can be specified. The cables are rated at up to 45W/m and 277V. The equipment is designed to be connected to a supply by means of suitable certified cable entries and junction boxes (i.e. Ex e or Ex d) in accordance with the manufacturer's installation instructions. Termination can be made using any suitably certified type termination kit, which fully isolate, insulate and seal the conductive cores. The heat trace cable is also allowed to be used with the termination kits (IECEx SIR 11.0135X, IECEx SIR 11.0136U and IECEx SIR 11.0137X).

See EQUIPMENT (continued) for additional information and Conditions of Manufacture

CONDITIONS OF CERTIFICATION: NO



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 11.0126

Date of Issue: 2012-02-28

Issue No.: 0

Page 4 of 4

EQUIPMENT(continued):

Additional Rating Information

- * Applicable for products rated up to 45 W/m and for nominally rated 230V products up to 45W/m powered up to a maximum 277V
- * Ex e IIC T4 Gb
- * Ex tb IIIC T135°C Db IP67

Description	Temperature
Max. continuous exposure temperature (Power ON)	100°C
Max. permissible exposure temperature (Power OFF)	100°C
Minimum installation temperature	-40°C

Conditions of manufacture

The Manufacturer shall comply with the following:

1. An electric strength test of $\sqrt{2} U + 1000$ V rms shall be applied between the conductors and the outer braid or jacket as appropriate for 60 seconds as required by clause 5.1.2 of IEC 60079-30-1:2007.
2. An electric strength test of the polymeric sheath (overjacket) used for corrosion resistance shall be carried out in accordance with the requirements of IEC 60079-30-1:2007 clause 5.2.1.
3. The manufacturer shall verify the output rating for each cable manufactured in accordance with IEC 60079-30-1-2007 clause 5.2.2.
4. The manufacturer shall demonstrate, through their quality program, the thermal safety of the trace heating cable with respect to time as per EN 60079-30-1:2007 clause 5.1.12.